



## DECLARATION OF PERFORMANCE



### DOP-FD-C-04

1. Unique identification code of the product-type:  
**FD-C fire damper** (see table below for specific damper installation type)  
**To be used in conjunction with walls/partitions/floors to maintain fire compartments in heating, ventilating and air conditioning installations**
2. Name, registered trade name or registered trade mark and contact address of the manufacturer as required under Article 11(5) of the CPR (Regulation (EU) no 305/2011):  
**BSB Engineering Services Ltd,**  
**Unit 56, Mill Way, Trinity Trade Centre, Sittingbourne, Kent, ME10, 2PD**
3. System or systems of assessment and verification of constancy of performance of the construction product as set out in the CPR, Annex V:  
**System 1**
4. In case of the declaration of performance concerning a construction product covered by a harmonized standard:  
**BRE Global Assurance (Ireland) Ltd (2831) performed the determination of the product type on the basis of type testing (including sampling), type calculation, tabulated values or descriptive documentation of the product, the initial inspection of the manufacturing plant and of factory production control and continuous surveillance, assessment and evaluation of factory production control under system 1 and issued the certificate of constancy of performance of the factory production control (no. CPR-P0008).**
5. Declared performance according to:  
**EN 15650 (Ventilation for Buildings – Fire Dampers)**

Essential Characteristics	Performance
<b>Fire resistance according to EN 1366-2 and classifications according to EN 13501-3:</b>	
<b>Range</b>	<b>Type</b>
100mm up to 315mm diameter	FD-C
100mm up to 315mm diameter	FD-C
100mm up to 315mm diameter	FD-C
<b>Supporting construction</b>	<b>Classification report</b>
Masonry Wall	287720 A/3 & C/3
Drywall Partition	287720B/1
Concrete Floor	P102289-1001
<b>Classification (BS EN 13501-3)</b>	E 120 (ve l ↔ o) S
E 90 (ve l ↔ o) S	E 120 (ho l → o) S
<b>Nominal activation conditions/sensitivity according to ISO 10294-4:</b>	
- sensing element load bearing capacity - sensing element response time	Pass Pass
<b>Response delay (response time) according to EN 1366-2:</b>	
- closure time	Pass
<b>Operational reliability according to EN 1366-2:</b>	
- cycling	Pass (50 cycles)
<b>Durability of response delay according to ISO 10294-4:</b>	
- sensing element response temperature and load bearing capacity	Pass

 Harmonised technical specification:  
 EN 15650:2010

Signed for and on behalf of BSB by:

Date: 21<sup>st</sup> April 2020

Mike Backham  
 Technical Director  
 BSB Engineering Services Ltd

