



DECLARATION OF PERFORMANCE



DOP-FD-05

- Unique identification code of the product-type:
FD fire damper (see table below for specific damper installation type)
To be used in conjunction with walls/partitions/floors to maintain fire compartments in heating, ventilating and air conditioning installations
- Name, registered trade name or registered trade mark and contact address of the manufacturer as required under Article 11(5):
**BSB Engineering Services Ltd,
Unit 56, Mill Way, Trinity Trade Centre, Sittingbourne, Kent, ME10, 2PD**
- System or systems of assessment and verification of constancy of performance of the construction product as set out in CPR, Annex V:
System 1
- In case of the declaration of performance concerning a construction product covered by a harmonized standard:
BRE Global Ltd (0832) performed the determination of the product type on the basis of type testing (including sampling), type calculation, tabulated values or descriptive documentation of the product, the initial inspection of the manufacturing plant and of factory production control and continuous surveillance, assessment and evaluation of factory production control under system 1 and issued the certificate of constancy of performance of the factory production control (no. CPR-P0006).
- Declared performance according to:
EN 15650 (Ventilation for Buildings – Fire Dampers)

Essential Characteristics				Performance
Fire resistance according to EN 1366-2 and classifications according to EN 13501-3:				
Range	Type	Supporting construction	Ref	Classification (BS EN 13501-3)
100 x 100mm up to 1200 x 1000mm	FD-AF	Drywall	287718A/2	E 120 (ve i ↔ o)
100 x 100mm up to 1200 x 1000mm	FD-AF	Masonry Wall	287718A/2	E 120 (ve i ↔ o)
2 x 2 Multiple arrangement	FD-AF	DryWall	P101872-1000-1	E 120 (ve i ↔ o)
100 x 100mm up to 1200 x 1000mm	FD-AF	Concrete Floor	287718B/1	E 120 (ho i → o)
100 x 100mm up to 1200 x 1000mm	FD-PF / FD-CL	Drywall	P100960-1006A/1	E 60 (ve i → o)
101 x 100mm up to 1200 x 1000mm	FD-PF / FD-CL	Masonry Wall	P100960-1006A/1	E 60 (ve i → o)
100 x 100mm up to 1200 x 1000mm	FD-HF	Masonry Wall	274347/2	E 120 (ve i → o)
100 x 100mm up to 1200 x 1000mm	FD-HF	Concrete Floor	274347/2	E 120 (ho i → o)
Nominal activation conditions/sensitivity according to ISO 10294-4: - sensing element load bearing capacity - sensing element response time				Pass Pass
Response delay (response time) according to EN 1366-2: - closure time				Pass
Operational reliability according to EN 1366-2: - cycling				Pass (50 cycles)
Durability of response delay according to ISO 10294-4: - sensing element response temperature and load bearing capacity				Pass

Harmonised technical specification:
EN 15650:2010

Signed for and on behalf of BSB by:

Date: 25th April 2017

Mike Backham
Technical Director
BSB Engineering Services Ltd

