



DECLARATION OF PERFORMANCE



DOP-AT-FSD-02

- Unique identification code of the product-type:
AT-FSD Air Transfer – Fire/Smoke Damper (see table below for specific damper installation type)
To be used in conjunction with walls/partitions to maintain fire compartments in heating, ventilating and air conditioning installations
The original product name was ‘ECD’. Renamed to AT-FSD
- Name, registered trade name and contact address of the manufacturer as required under Article 11(5) of the CPR (Regulation (EU) no 305/2011):
BSB Engineering Services Ltd,
Unit 56, Mill Way, Trinity Trade Centre, Sittingbourne, Kent, ME10, 2PD
- System or systems of assessment and verification of constancy of performance of the construction product as set out in the CPR, Annex V:
System 1
- In case of the declaration of performance concerning a construction product covered by a harmonized standard:
BRE Global Assurance (Ireland) Ltd (2831) performed the determination of the product type on the basis of type testing (including sampling), type calculation, tabulated values or descriptive documentation of the product, the initial inspection of the manufacturing plant and of factory production control and continuous surveillance, assessment and evaluation of factory production control under system 1 and issued the certificate of constancy of performance of the factory production control (no. 2831-CPR-P00016).
- Declared performance according to:
EN 15650 (Ventilation for Buildings – Fire Dampers)

Essential Characteristics				Performance	
Fire resistance according to EN 1366-2 and classifications according to EN 13501-3:					
Range (W X H)	Type	Supporting construction	Classification report	Classification (BS EN 13501-3)	
200 x 175mm up to 1000 x 300mm	AT-FSD	Drywall Partition	20/23919-3097	E 120 (ve l → o) S	
200 x 175mm up to 1000 x 300mm	AT-FSD	Masonry Wall	20/23919-3097	E 120 (ve l → o) S	
Nominal activation conditions/sensitivity according to ISO 10294-4: - sensing element load bearing capacity - sensing element response time				Pass Pass	
Response delay (response time) according to EN 1366-2: - closure time				50 Cycles Pass	
Operational reliability according to EN 1366-2: - cycling				Pass	
Durability of response delay according to EN 1366-2: - sensing element response temperature and load bearing capacity				Pass	
Durability of operational reliability according to EN 15650: - open and closing cycle				10,000 cycles Pass	

Harmonised technical specification:
EN 15650:2010

Signed for and on behalf of the manufacturer by:

Date: 8th February 2022

Mike Backham
Technical Director
BSB Engineering Services Ltd

